Salisbury Township, Lehigh County Private BMP Annual Inspection Form CONVEYANCE SYSTEMS (PIPES & DITCHES)

Inspection Date:				
Address:				
Owner:	_ Contact:			
Phone: Email:				
Maintenance Contractor: Yes No		HOA:	Yes	No
Contractor Name:				
Contractor Address:				
Phone: Email:				

INSPECTION INSTRUCTIONS:

- Each BMP requires a separate inspection form.
- A photo of each BMP is required with the inspection form.
- Before and after photos for BMPs requiring maintenance.
- Complete the checklist that corresponds with the specific BMP.

CHECKLIST:			
Condition	Condition Requires Maintenance When:		Maintenance Performed Yes or No
Sediment & debris	Accumulated sediment that exceeds 20% of the pipe diameter.		
Vegetation	Vegetation that reduces free movement of water through pipes.		
Damaged pipe	Protective coating is damaged; rust is causing more than 50% deterioration to any part of pipe.		
	Any dent that decreases the cross-section area of pipe by more than 20% or puncture that impacts performance.		
OPEN DITCHES			
Trash & debris	Trash and debris >5 cf/1,000 sf (one standard garbage size can) Visual evidence of dumping.		
Sediment	Accumulated sediment that exceeds 20% of design depth.		
Vegetation	Vegetation that reduces free movement of water through ditches.		

OPEN DITCHES			
Condition	Requires Maintenance When:	Maintenance Required Yes, No or N/A	Maintenance Performed Yes or No
Erosion damage to slopes and channel bottom	Eroded damage over 2 inches deep where cause of damage is still present or where there is potential for continued erosion. Any erosion observed on a continued berm embankment.		
Rock lining out of place or missing (if applicable)	Maintenance person can see native soil beneath the rock lining.		

Notes or Comments:	 		