Salisbury Township, Lehigh County Private BMP Annual Inspection Form SAND FILTERS (Above Ground)

Inspection Date:				
Address:				
Owner:	Contact:			
Phone:	Email:			
Maintenance Contractor: Yes No		HOA:	Yes	No
Contractor Name:				
Contractor Address:				
Phone: Email:				

INSPECTION INSTRUCTIONS:

- Each BMP requires a separate inspection form.
- A photo of each BMP is required with the inspection form.
- Before and after photos for BMPs requiring maintenance.
- Complete the checklist that corresponds with the specific BMP.

CHECKLIST:			
Condition	Condition Requires Maintenance When:		Maintenance Performed Yes or No
GENERAL CONDITION	DN		
Sediment accumulation on top layer	Sediment depth exceeds ½ inch.		
Trash and debris accumulation	Trash and debris accumulated on sand filter bed.		
Sediment / debris in clean-outs	When the clean-outs become full or partially plugged with sediment and or debris.		
Sand filter media	Drawdown of water through the sand filter media takes longer than 24-hours, and or flow through the overflow pipes occurs frequently.		
Prolonged flows	Sand is saturated for prolonged periods of time (several weeks) and does not dry out between storms due to continuous base flow or prolonged flows from detention facilities.		
Short circuiting	When flows over 2 inches deep where cause of damage is prevalent or potential for continued erosion is evident.		

FENCING			
Condition	Requires Maintenance When;	Maintenance Required Yes, No or N/A	Maintenance Performed Yes or No
Rock Pad missing or out of place	Soil beneath the rock is visible.		
Flow Spreader	Flow Spreader uneven or clogged so that flows are not uniformly distributed across sand filter.		
Damaged Pipes	Any part of the piping that is crushed or deformed more than 20% or any other failure to the piping.		

Notes or Comments:		 	