Salisbury Township, Lehigh County Private BMP Annual Inspection Form

WET BIOFILTRATION SWALE

Inspection Date:				
Address:				
Owner:	Contact:			
Phone:	Email:			
Maintenance Contractor: Yes No		HOA:	Yes	No
Contractor Name:				
Contractor Address:				
Phone: Email:				

INSPECTION INSTRUCTIONS:

- Each BMP requires a separate inspection form.
- A photo of each BMP is required with the inspection form.
- Before and after photos for BMPs requiring maintenance.
- Complete the checklist that corresponds with the specific BMP.

CHECKLIST:							
Condition	Requires Maintenance When:	Maintenance Required Yes, No or N/A	Maintenance Performed Yes or No				
GENERAL							
Sediment accumulation	Sediment depth exceeds 2 inches in 10% of the swale treatment area.						
Water depth	Water not retained to a depth of about 4 inches during the wet season.						
Wetland vegetation	Vegetation becomes sparse and does not provide adequate filtration or vegetation is crowded out by very dense clumps of cattail, which do not allow water to flow through clumps.						
Inlet / outlet	Inlet / outlet area clogged with sediment and or debris.						
Trash and debris	Trash and debris accumulated in bioswale.						
Erosion / scouring	Swale has eroded or scoured due to flow channelization, or higher flows.						

Notes or Comments:			